

October 10, 2018

Mr. Gary Delger  
Caledonia Community Schools  
8944 Kraft Ave  
Caledonia, MI 49316

RE: Early Childhood Center

Dear Mr. Gary Delger:

Prein&Newhof Laboratory received 2 sample(s) on 10/5/2018 for the analyses presented in the following report.

All of the regulated parameters have been analyzed using EPA approved methods.

We are certified by the State of Michigan for drinking water analysis for: Coliform Bacteria, Metals, Cyanide, Minerals, Anions, Volatile Organics, THM's, Haloacetic Acids, and PNA's.

Michigan Lab ID#: 0020

EPA Lab #: MI000014

Analytes received and/or analyzed out of holding times are noted by a "H" in the Qual field.

Analytical results designated with a "J" qualifier are estimated and represent a detection above the Method Detection Limit (MDL) and less than the Reporting Limit (PQL).

Any analyte that exceeds the EPA Maximum Contaminant Level are noted on the report with an "\*" in the Qual field.

The sample results associated with the attached report meet the safe drinking water criteria for the analytes reported unless indicated by a "\*" in the Qual field.



Steve Bylsma  
Laboratory Manager

---

**CLIENT:** Caledonia Community Schools **Lab Order:** 1810299  
**Project:** Early Childhood Center

---

**Lab ID:** 1810299-01 **Matrix:** DRINKING WATER **Collection Date:** 10/5/2018 7:49:00 AM  
**Client ID:** Room #119 Kids Sink **Sampler:** S. Horka **Received Date:** 10/5/2018 9:40:00 AM

Analyses	Result	PQL	Qual	Units	MCL	Date Analyzed
<b>COPPER, DRINKING WATER</b>				<b>EPA 200.7</b>		Analyst: <b>SB</b>
Copper	1.04	0.0100		mg/L	1.30	10/9/2018 12:30:00 P
<b>LEAD, DRINKING WATER</b>				<b>SM 3113B</b>		Analyst: <b>SB</b>
Lead	< 0.00300	0.00300		mg/L	0.0150	10/9/2018 9:28:35 AM

---

**Lab ID:** 1810299-02 **Matrix:** DRINKING WATER **Collection Date:** 10/5/2018 8:00:00 AM  
**Client ID:** Room #806 East Sink **Sampler:** S. Horka **Received Date:** 10/5/2018 9:40:00 AM

Analyses	Result	PQL	Qual	Units	MCL	Date Analyzed
<b>COPPER, DRINKING WATER</b>				<b>EPA 200.7</b>		Analyst: <b>SB</b>
Copper	0.959	0.0100		mg/L	1.30	10/9/2018 12:30:00 P
<b>LEAD, DRINKING WATER</b>				<b>SM 3113B</b>		Analyst: <b>SB</b>
Lead	0.00931	0.00300		mg/L	0.0150	10/9/2018 9:28:35 AM

---

**Qualifiers:** \* Value exceeds Maximum Contaminant Level.  
 D Dilution was required.  
 J Analyte detected below quantitation limits  
 PL Permit Limit

< Not Detected at the Reporting Limit  
 H Holding times for preparation or analysis exceeded  
 MCL Maximum Contaminant Level  
 PQL Practical Quantitation Limit

Original  
 Page 2 of 2